Rec. 13/2/12

ARW Design

89, South Street

Tarring

Worthing

West Sussex

BN14 7ND

Phone Number +44(0)1903234197

E-Mail Arweeden1@aol.com

www.arwdesign.co.uk

12th March 2012

Dear Carlos

Re: 16, Bristol Avenue, Lancing. AWDM/0236/12

In response to your E mail dated 5th March regarding flooding in this vicinity I have attached the Environment Agency form FRSA009a.

The substructure specification is as follows:-

Mass concrete trench fill with engineering bricks to DPC level

Ground supported floor with sand/cement screed to receive finish on concrete oversite, on Celotex insulation, on polythene DPM on sand blinding, on hardcore to ground level. Floor finished with slight slope to East elevation.

Cavity walls of Celcon blockwork (or similar) with sand/cement exterior render, partial Celotex cavity fill & plaster internally.

All electrical wall sockets will be raised accordingly.

Yours Sincerely

ALLEN WEEDEN

ADUR & WORTHING PLANNING SERVICES	
PLAN	AWDM/ 0236/12
DATE VALID	13 MAR 2012