Please see attached electrical load schedule which shows that we can accommodate (1300kVA) to remain within the target electrical load on site.

Total quantity 19No. of which 11No. are active/fitted, 8No. are passive (ducted & electrical load allowed for but not wired or fitted) – updated drawing also attached.

It is not possible to install any more than this due to not having the power on site.