From: Gary Peck <gary.peck@adur-worthing.gov.uk> on behalf of Gary Peck
Sent: 14 September 2023 16:38
To: Planning -
Subject: Fwd: AWDM/1080/23 - St Nicolas And St Mary C E Primary School, Eastern Avenue, Shoreham-by-sea

Flag Status: Flagged

---------- Forwarded message ---------
From: **Tessa Denny** <tessa.denny@adur-worthing.gov.uk>
Date: Thu, 14 Sept 2023 at 15:44
Subject: AWDM/1080/23 - St Nicolas And St Mary C E Primary School, Eastern Avenue, Shoreham-by-sea
To: Gary Peck <gary.peck@adur-worthing.gov.uk>

Hi Gary,


Could we please request further details on the noise produced by the new plant - ie the breakout beyond the GRP enclosure from the new plant/ This should include a frequency analysis of the noise produced.


The proposed location is within 15m of number 95's garden and so want to ensure the noise is not a problem at night, especially the frequency characteristics.

Kind regards

--

Tessa Denny
Environmental Health Technician, Public Health & Regulation
01273 263357
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
www.adur-worthing.gov.uk





--

Gary Peck
Planning Services Manager, Planning & Development
1903221406

Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
http://www.adur-worthing.gov.uk

