Southern Water

Planning Services
Adur and Worthing Councils
Portland House
Richmond Road
Worthing
West Sussex
BN11 1LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119
Email: developerservices@southernwater.co.uk

Your Ref
AWDM/0085/16
Our Ref
PLAN-012797
Date
18/02/2016

Dear Sirs,

Proposal: Application to vary condition 14 of AWDM/0431/14 to vary the trading hours to allow trading 8am to 10pm.
Site: Unit 1, Malthouse Trading Estate, Brighton Road, Shoreham-By-Sea, West Sussex, BN43 6RJ.
AWDM/0085/16

Thank you for your letter of 29/01/2016.

Southern Water has no objections to the above variation of condition 14 submitted by the applicant.

Please be advised that the proposed development lies within close proximity to the public water main (please see attached plan). No development or tree planting is allowed with 4 metres either side of the centreline of the water mains and 3 metres either side of the centreline of the foul rising main. Any works within the clearance distance would require Southern Water's approval. We request the protection measures for the public apparatus to be submitted to and approved by Southern Water.

Yours sincerely

Developer Services