From: Michael Lavender
Sent: 13 October 2011 11:45
To: Peter Barnett
Subject: RE: noise report Parcelforce

Hi Peter,

In the absence of any formal noise report or noise mitigation scheme from the applicant, I would advise that the following condition be attached to any planning permission granted.

Noise from music shall not exceed 55dB LAeq (F) 1 hour as measured 1.5m from the Southern façade of the premises. (or words to this effect)

I would also advise that an hours of use also be placed on the development to ensure the site is closed at 10pm.

Regards

Michael

-----Original Message-----
From: Peter Barnett
Sent: 13 October 2011 10:23
To: Michael Lavender
Subject: FW: noise report Parcelforce

Michael

Report attached

Thanks

Peter

Peter Barnett - Principal Planning Officer Development Management, Adur District Council
Location: Portland House, Richmond Road, Worthing, West Sussex BN11 1LF
Internal: (8) 1310 | External: 01903 221310 | E-mail: peter.barnett@adur-worthing.gov.uk
Please think before you print this and save paper

-----Original Message-----
From: Planning_MFD@adur-worthing.gov.uk [mailto:Planning_MFD@adur-worthing.gov.uk]
Sent: 13 October 2011 09:15
To: Peter Barnett
Subject:

This E-mail was sent from "RNPD4B93E" (MPC3500/DSc535).

Scan Date: 13.10.2011 10:15:18 (+0200)
Queries to: Planning_MFD@adur-worthing.gov.uk