From: Hannah Powell <hannah.powell@adur-worthing.gov.uk> on behalf of Hannah Powell
Sent: 02 August 2021 14:18
To: Peter Barnett
Subject: AWDM/1182/21

Flag Status: Flagged

Peter
With reference to the above application further information is required concerning the impact of the lighting on surrounding residential dwellings. The applicant advises the new LED lights will reduce light pollution in the local area but no information has been provided to demonstrate this.

Please could the applicant confirm the times when the lights will be in use?

Due to the relative proximity of existing residential premises there is the potential for the new lights to cause a loss of amenity as a result of light spillage and glare. I would recommend the following condition:

Prior to installation, details of the external lighting of the site shall be submitted to and approved in writing by the Local Planning Authority. These details shall include the predictions of both horizontal illuminance across the site and vertical illuminance affecting immediately adjacent receptors. The lighting installation shall comply with the recommendations of the Institution of Lighting Professionals (ILP) "Guidance Notes for the Reduction of Obtrusive Light" (2011).

Regards
--

Hannah Powell
Environmental Health Technician, Adur & Worthing Councils
Phone: 01273 263357
Email: hannah.powell@adur-worthing.gov.uk
Website: http://www.adur-worthing.gov.uk/
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



