From: Nadeem Shad <nadeem.shad@adur-worthing.gov.uk> on behalf of Nadeem Shad
Sent: 09 November 2023 09:42
To: Peter Barnett
Subject: Re: AWDM/2136/20 & 2138/20 Town Hall Chambers, Shoreham

Flag Status: Flagged

Hi Peter,

I have looked at the revised and updated acoustic report dated 05/10/2023. I agree with the conclusions and recommendations contained in section 10.5 and recommend they are implemented in full.

For the sound insulation: *The sound insulation of the floor/ceiling between the ground and first floor shall achieve a minimum airborne sound insulation value of 50dB (DnTw + Ctr dB). Before the residential units are occupied a test shall be undertaken to demonstrate compliance with this level.*

Regards
Nadeem

Nadeem Shad (he/him)
Team Leader Environmental Protection, Public Health & Regulation
01273 263303
Adur & Worthing Councils
Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA
http://www.adur-worthing.gov.uk/environmental-health/





On Thu, 9 Nov 2023 at 09:09, Peter Barnett <peter.barnett@adur-worthing.gov.uk> wrote:

> Hi
>
> Could I please chase your comments up for this one?
>
> thanks
>
> **Peter Barnett**
> Principal Planning Officer, Planning & Development
> 01903 221310
> Adur & Worthing Councils
> Portland House, 44 Richmond Road, Worthing, BN11 1HS
> http://www.adur-worthing.gov.uk





---------- Forwarded message ---------
From: **Peter Barnett** <peter.barnett@adur-worthing.gov.uk>
Date: Fri, 20 Oct 2023 at 08:09
Subject: Fwd: AWDM/2136/20 & 2138/20 Town Hall Chambers, Shoreham
To: Public Health and Regulation <publichealth.regulation@adur-worthing.gov.uk>

Hi

Please could I have your comments on the attached noise report?

Thanks

Peter Barnett
Principal Planning Officer, Planning & Development
01903 221310
Adur & Worthing Councils
Portland House, 44 Richmond Road, Worthing, BN11 1HS
http://www.adur-worthing.gov.uk





---------- Forwarded message ---------
From: **Gary Thompson** <GThompson@crowtherassociates.co.uk>
Date: Thu, 19 Oct 2023 at 16:52
Subject: RE: AWDM/2136/20 & 2138/20 Town Hall Chambers, Shoreham
To: Peter Barnett <peter.barnett@adur-worthing.gov.uk>

Dear Peter,

Please find attached the final element of additional information, on acoustics, requested by your environmental health colleague. That completes all additional information required and, as they replicate the original approvals, allows you to now confirm approval of these applications.

Many thanks for your help in this.

Regards

Gary

Gary Thompson
Consultant

Crowther Associates Architects LLP
Pelham House, 25 Pelham Square, Brighton. BN1 4ET.
T 01273 695535
M 07802 923533
E gthompson@crowtherassociates.co.uk
W www.crowtherassociates.co.uk

Crowther Associates Architects is a Limited Liability Partnership registered in England & Wales. Registration No. OC338155. Registered office: 25 Pelham Square, Brighton. BN1 4ET. This e mail may contain privileged or confidential information: if you are not the intended recipient or have received this in error any dissemination of it is prohibited. Please notify the sender immediately or call 01273 695535 and delete it from your system.

Think before you print – do you really need to print this email? Please consider the environment.