From: Bruce Reynolds
Sent: 02 July 2010 15:26
To: Peter Barnett
Subject: ADC/0211/10: First-floor rear extension to form an additional flat (one-bedroom) (153-155)

Dear Peter

I have now had the opportunity to review the above application and would make the following comments.

The alterations will have the effect of making the existing bathroom internal and so mechanical extraction would be required to prevent condensation problems. The noise from such a system would need to be properly controlled.

There is insufficient provision for the storage of waste on the site.

If you require any further information, please do not hesitate to contact me.

Yours sincerely

Bruce Reynolds
Senior Environmental Health Officer
Adur District Council

Tel: (01273) 263098: Fax: (01273) 263014 : e-mail : bruce.reynolds@adur.gov.uk
---
Domestic & Pollution Team
Housing, Health & Community Safety
Room 116, Civic Centre, Ham Road, Shoreham-by-Sea, West Sussex BN43 6PR

You can visit Adur DC's website at: http://www.adur.gov.uk

Please consider the environment, only print out this e-mail if absolutely necessary.