From: **Public Health and Regulation** <publichealth.regulation@adur-worthing.gov.uk>
Date: Tue, 16 Apr 2024 at 12:02
Subject: Fwd: FW: 6 Windsor Road - Planning Condition AWDM/0611/20
To: Louise Prew <louise.prew@adur-worthing.gov.uk>
Cc: Nadeem Shad <nadeem.shad@adur-worthing.gov.uk>

Hi Louise,

your e-mail has found its way to me as an action on one of my closed worksheets.

I am not an architectral trained acousticians, but looking at the consultation information we received the applicant has advised that the insulation works will exceed current building regulations ADE requirement of 43dB by 16dB. They are predicting a sound reduction of 56dB. For this reason I have no objections to what is being proposed.

I note there is only one habitable room sharing a party wall with the neighbouring property, which I understand has been converted into flats, and this is a first floor bedroom. I don't know what is on the other side of the party wall shared with this bedroom. The stair case, corridors and kitchen make up the other spaces sharing the party wall. It may be worth checking whether Building Control will sign off the renovation works, as it is for sound insulation. It is not something this dapartment would look at.

If the neighbour making the request is concerned that mounting kitchen cupboards on the party wall will affect the sound insulation, then maybe this question should be put to the applicant for an explanation.

Regards

Michael Lavender