

Design Settings

Rainfall Methodology	FEH-22	Minimum Velocity (m/s)	1.00
Return Period (years)	100	Connection Type	Level Soffits
Additional Flow (%)	0	Minimum Backdrop Height (m)	0.200
CV	1.000	Preferred Cover Depth (m)	1.200
Time of Entry (mins)	5.00	Include Intermediate Ground	✓
Maximum Time of Concentration (mins)	30.00	Enforce best practice design rules	✓
Maximum Rainfall (mm/hr)	50.0		

Nodes

Name	Area (ha)	T of E (mins)	Cover Level (m)	Easting (m)	Northing (m)	Depth (m)
Permeable Paving_Double Driveway	0.005	5.00	10.000	11.495	75.877	0.700

Simulation Settings

Rainfall Methodology	FEH-22	Analysis Speed	Normal	Starting Level (m)	
Rainfall Events	Singular	Skip Steady State	x	Check Discharge Rate(s)	x
Summer CV	1.000	Drain Down Time (mins)	240	Check Discharge Volume	x
Winter CV	1.000	Additional Storage (m³/ha)	0.0		

Storm Durations

15 | 30 | 60 | 120 | 180 | 240 | 360 | 480 | 600 | 720 | 960 | 1440 | 2160

Return Period (years)	Climate Change (CC %)	Additional Area (A %)	Additional Flow (Q %)
2	0	0	0
10	0	0	0
30	40	0	0
100	45	0	0

Node Permeable Paving_Double Driveway Carpark Storage Structure

Base Inf Coefficient (m/hr)	0.11520	Invert Level (m)	9.300	Slope (1:X)	20.0
Side Inf Coefficient (m/hr)	0.00000	Time to half empty (mins)	40	Depth (m)	0.400
Safety Factor	2.0	Width (m)	3.400	Inf Depth (m)	0.100
Porosity	0.30	Length (m)	12.900		



Results for 2 year Critical Storm Duration. Lowest mass balance: 100.00%

Node Event	US Node	Peak (mins)	Level (m)	Depth (m)	Inflow (l/s)	Node Vol (m³)	Flood (m³)	Status
120 minute summer	Permeable Paving_Double Driveway	74	9.515	0.215	0.5	0.3109	0.0000	OK
Link Event (Upstream Depth)	US Node	Link	Outflow (l/s)					
120 minute summer	Permeable Paving_Double Driveway	Infiltration	0.2					

Results for 10 year Critical Storm Duration. Lowest mass balance: 100.00%

Node Event	US Node	Peak (mins)	Level (m)	Depth (m)	Inflow (l/s)	Node Vol (m ³)	Flood (m ³)	Status
60 minute summer	Permeable Paving_Double Driveway	42	9.632	0.332	1.3	0.7227	0.0000	OK

Link Event (Upstream Depth)	US Node	Link	Outflow (l/s)
60 minute summer	Permeable Paving_Double Driveway	Infiltration	0.4

Results for 30 year +40% CC Critical Storm Duration. Lowest mass balance: 100.00%

Node Event	US Node	Peak (mins)	Level (m)	Depth (m)	Inflow (l/s)	Node Vol (m³)	Flood (m³)	Status
60 minute summer	Permeable Paving_Double Driveway	44	9.787	0.487	2.4	1.5284	0.0000	OK
Link Event (Upstream Depth)	US Node	Link	Outflow (l/s)					
60 minute summer	Permeable Paving_Double Driveway	Infiltration	0.5					

Results for 100 year +45% CC Critical Storm Duration. Lowest mass balance: 100.00%

Node Event	US Node	Peak (mins)	Level (m)	Depth (m)	Inflow (l/s)	Node Vol (m³)	Flood (m³)	Status
60 minute summer	Permeable Paving_Double Driveway	45	9.875	0.575	3.2	2.1214	0.0000	OK
Link Event (Upstream Depth)	US Node	Link	Outflow (l/s)					
60 minute summer	Permeable Paving_Double Driveway	Infiltration	0.6					