



Adur & Worthing Council
Portland House
44 Richmond Road
Worthing
West Sussex
BN11 1HS

Your ref
AWDM/0396/26

Our ref
DSA000054944

Date
19th June 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Demolition of existing buildings and construction of a three-storey building comprising 27 1-bed apartments

Site address: 10 - 20 Marine Place Worthing West Sussex BN11 3DN

Proposed works involve demolition:

In order to protect and safeguard the existing water supply apparatus, Southern Water requests formal notification of any proposed demolition works prior to such works being undertaken.

Proposed SUDS features:

If it is the intention of the developer for Southern Water to adopt the proposed SuDS, the system shall be designed and constructed in line with the Design and Construction Guidance www.water.org.uk/sewerage-sector-guidance-approved-documents/.

No Soakaways should be connected to the public surface water sewer.

Build over:

'The attached plan shows that the proposed development is being built over a public sewer. An investigation of the sewer is required to confirm its size and depth, ascertain its condition, number of properties served and potential means of access before any decision can be made as to whether it would be acceptable for the proposed development to be built close to the sewer. If the sewer in question is found to be no greater than 225mm in diameter and no deeper than 3 meters, the development may be allowed, subject to the following conditions:

1. No construction works parallel to the sewer within 500mm (in plan).
2. Where within three metres, foundations depth to be taken down 150mm below the invert level of the sewer.

The works will be subject to approval under the 'Declaration of Works' self-certification process.



It appears that the developer is intending to build close to a public foul sewer which is crossing the site. Building over a “public sewer” is not normally permitted by Southern Water. However, under certain circumstances building over a minor sewer may be allowed. The conditions and application associated with the build-over/close-to a public sewer are available at Southern Water's Get Connected service: <https://developerservices.southernwater.co.uk>.

Condition:

'In order to protect drainage apparatus, Southern Water requests that if consent is granted, the following condition is attached to the planning permission; prior to the commencement of development, the developer must advise the local authority, in consultation with Southern Water, of measures which will be undertaken to protect the public sewers.

Connection to public sewer - capacity available desktop study under 50:

Southern Water has undertaken a desktop study of the area, and our investigations indicate that Southern Water can facilitate foul sewerage /surface water run off disposal to service the proposed development. Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service:

<https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link:

<https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by the Local Planning Authority in consultation with Southern Water.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site. If this happens, please call our Customer Service Desk on 0330 303 0119.

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team southernwater.co.uk/developing-building/planning-your-development